ARIZONA DEPARTMENT OF WATER RESOURCES
Office of Assured and Adequate Water Supply
3550 North Central Avenue, Phoenix, Arizona 85012
Telephone 602 771-8500
Fax 602 771-8689

September 11, 2006

Janet Napolitano
Governor

Herbert R. Guenther
Director

Mr. Roy Tanney
Arizona Department of Real Estate
2910 N. 44th Street
Phoenix, Arizona 85018

Water Adequacy Report #22-4022150000
Subdivision Name: Alborada
Owner: Jesus & Cristela Tovar
Number of lots: 12
County: Yuma
Township 10 S **Range** 24 W **Section** 04

Water provided by: City of Somerton
Water Type: Groundwater
Current water depth: 10 to 75 feet below land surface
Estimated 100-year depth: 123 to 141 feet below land surface
Current decline rate: No declines
Basin: Yuma

Dear Mr. Tanney:

Pursuant to A.R.S. § 45-108, the Department of Water Resources has reviewed the available information pertaining to the water supply for the above-referenced subdivision. This letter constitutes the Department's report on the subdivisions water supply as required by A.R.S. § 45-108(A).

Adequacy of the 100-year water supply was reviewed by the Department with regard to physical, legal and continuous availability, and to determine if the water supply is of adequate quality. Information available to the Department indicates that the applicant has satisfied the adequate water supply requirements as set forth in A.A.C. R12-15-715 *et seq.* Therefore, the Department of Water Resources finds the water supply to be adequate to meet the subdivision's projected needs. Any change to the subdivision or its water supply plans may invalidate this decision.

This letter is being forwarded to your office as required by A.R.S. § 45-108. This law requires the developer to hold the recordation of the subdivision's plat until receipt of the Department's report on the subdivision's water supply. By copy of this report, the Yuma County Recorder is being officially notified of the developer's compliance with the law. Because of the possibility that a future court proceeding could result in a legal determination that water withdrawn from wells in this area is surface water, the Department recommends that your office include the following statement in all promotional material and contracts for sale of lots in the subdivision:

> **"Pursuant to A.R.S. § 45-108 and A.A.C. R12-15-715 *et seq.*, the Department has determined that the water supply for the Alborada subdivision is <u>adequate</u>, *i.e.* that the water supply is physically, continuously and legally available to satisfy the applicant's 100-year projected water demand, and that the water supply is of suitable water quality. However, the legal availability of the water withdrawn from wells in this area may be the subject of court action in the future as part of a determination of surface water rights. Whether future court action will have an effect on the legal availability of the water supply for the proposed subdivision cannot be determined at this time."**

If you have any questions, please contact Brett Shaner at (602) 771-8500.

Sincerely,

Frank Putman
Assistant Director

FP/RO/ef
700374

cc: Yuma County Planning and Zoning
Yuma County Recorder
Vianey R Vega
Rick Obenshain, ADWR